

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215487
Address: 2002 SW 26TH TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mitchell Schwarz	Failed	Monday, September 12, 2022

Corrective Action Required:

1	Misc	-gates to be self closing -no gaps greater than 4" at fence -connect downspouts -occupancy load signs -downspouts to extend 36" from foundation -complete grounding/bonding at all light poles -provide non absorbent finish within 2' of fixtures
---	------	--

Comments: