

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203779
Address: 2334 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|-------------------------------------|------------------|----------|----------------------------|
| Water Service Inspection - R | Mitchell Schwarz | Passed | Monday, September 12, 2022 |

Informational:
1 Misc Only partial approval at the time of installation due to meter box lid is currently below grade. Will revisit the issue at final to ensure meter box lid is accessible at grade and meter is 14-18" below lid

Comments: