

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211621
Address: 2333 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Not Ready	Monday, September 12, 2022

Corrective Action Required:

1	Misc	TCO EXPIRED SUBMIT TCO EXTENSION REQUEST FORM
		-pay all fees
		-(2) 1/2" through bolts required at deck post to beam connections
		-address siding from ground
		-provide access to back yard for viewing

Comments: