

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215064
Address: 3713 SW MARYVILLE PL, LEES SUMMIT, MO 640823715 SW MARYVILLE PL, LEES SUMMIT, MO
640823717 SW MARYVILLE PL, LEES SUMMIT, MO 640823711 SW MARYVILLE PL, LEES
SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Monday, September 12, 2022

Corrective Action Required:

1	Misc	-maintain erosion control -resolve outstanding inspection fees -final grade and sod -splash blocks -Sump pump discharge 36" from foundation
		UNIT 3717: -hammer arrestor for dishwasher -provide code required access for sump pump at crawl space, shield light fixture at crawl space -check GFCI fixture at rear beneath deck, no power at outlet -flood light at rear yard required, ORD 7-1409.2

Comments: