

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20224137  
Address: 1109 NE GOSHEN CT, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Monday, September 12, 2022

Corrective Action Required:

1	Misc	-Fb bathroom wall from fur down ceiling space -Flexible bathroom fan duct cannot exceed 14 ft per UL label. Switch to hard duct -Fb wall space from joist space and soffit space; provide vertical fire blocking at ten ft or less interval  **OK TO INSULATE
---	------	---

Comments: