



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20110115, Building Permit - Commercial
Address: 970 NW BLUE PKWY, Unit:A, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	David Landes	Partial	Monday, April 11, 2011

Corrective Action Required

1	MISC	- SHEET E2.0, LINE D - MISSING OUTLET IN SOFFIT.
Partial Correction		
2	MISC	- OKAY TO SHEETROCK EXCEPT AT LINE D SOFFIT

Comments: