

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215274

Address: 3695 NE AKIN DR, Unit:B, LEES SUMMIT, MO 640643695 NE AKIN DR, Unit:C, LEES SUMMIT, MO
640643695 NE AKIN DR, Unit:D, LEES SUMMIT, MO 640643695 NE AKIN DR, Unit:A, LEES
SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Khanh Nguyen	Failed	Tuesday, September 13, 2022

Informational:

1 Misc

Attic firewall-OK

Dwelling separation-Fire caulk wall penetrations at I beam

Comments: