

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211949
Address: 1422 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Tuesday, September 13, 2022

Corrective Action Required:

1	Misc	-resolve outstanding inspection fees -repair rock at garage wall left of outlet -mark dedicated receptacles as not GFCI protected -provide access jacuzzi tub motor at master bath -AFCI protection all breaker locations per code, IRC E3902.16, NEC 210.12(A) -remove all construction debris and silt fence at rear of lot
---	------	--

Comments: