

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204715
Address: 1820 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, September 13, 2022

Corrective Action Required:

1 Misc

- address piers poured without inspection
- pay all fees
- obtain lawn irrigation permit
- address pending driveway and sidewalk inspections
- spark ring at fire place outlet
- security screws at basement patio door
- (2)1/2" through bolts at each deck post to beam connection
- provide pan for water heater

Comments: