## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20212569

Address: 2353 SW HICKORY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Mitchell Schwarz Failed Tuesday, September

Residential 13, 2022

## Corrective Action Required:

1 Misc

- -address pending driveway inspection
- -obtain lawn irrigation permit
- -sod
- -splash blocks and sump pump discharge to extend 36" from foundation
- -seal all exterior penetrations
- -meter to be 14-18" from lid to top of meter
- -install spindles throughout home for inspection
- -GFCI protection for out under kitchen sink
- -spark rings at kitchen outlets where required by code
- -install security screws at rear door
- -handrail at deck stairs
- -deck steps to comply with code section
- -GFCI outlet in garage entry bath
- -outlet at garage entry, unfinished area left of water heater to be GFCI protected or labeled non GFCI and switches to single receptacle outlet
- -window fall protection for all up stairs bed rooms windows that require
- -afci breaker for living room sub panel
- -(2) 1/2" through bolts at each deck post to beam connection
- -address deck post to be contentious full height per plans
- -GFCI protection required at basement bathroom

**Comments:**