

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20213548  
Address: 2100 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Michael Harkins	Partial	Friday, September 02, 2022

Corrective Action Required:	
1      THIRD FLOOR	AREA "A" UNITS AND CORRIDOR APPROVED
Corrective Action Required:	
2      SECOND FLOOR	AREA A 209- Seal dead space 233- Nail corners
Corrective Action Required:	
3      FIRST FLOOR	BLDG # 1 LEVEL 1 AREA A 9/2/22 UNITS 123,124,125,126,127,128,130,132,134
Corrective Action Required:	
4      ELEVATOR 1	
Corrective Action Required:	
5      STAIR TOWER 1	-PROVIDE VERTICAL FIREBLOCKING MAX 10' OC AT SHARED WALL
Corrective Action Required:	
6      STAIR TOWER 2	-PROVIDE VERTICAL FIREBLOCKING MAX 10' OC AT SHARED WALL
Corrective Action Required:	
7      STAIR TOWER 3	
Corrective Action Required:	
8      STAIR TOWER 4	

**Comments:**