

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215066

Address: 2102 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822104 SW HOLDBROOKS DR, LEES SUMMIT,
MO 640822106 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822108 SW HOLDBROOKS
DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Not Ready	Tuesday, September 13, 2022

Corrective Action Required:

1	Misc	PROVIDE SCREW PATTERN AT ALL GB BRACED LOCATIONS PER PLANS/ IRC R60210.4, 7" OC EDGES (INCLUDING TOP AND BOTTOM PLATES) AND 7" OC FIELD
		UNIT 2102: SEE ABOVE, SCREW PATTERN PER GB BRACING DESIGN
		UNIT 2104: NOT READY FOR INSPECTION, HOUSE BEING ROCKED AT TIME OF INSPECTION

Comments: