

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215028

Address: 2603 NE MCBAINE DR, LEES SUMMIT, MO 640642605 NE MCBAINE DR, LEES SUMMIT, MO
640642607 NE MCBAINE DR, LEES SUMMIT, MO 640642609 NE MCBAINE DR, LEES
SUMMIT, MO 640642611 NE MCBAINE DR, LEES SUMMIT, MO 640642613 NE MCBAINE
DR, LEES SUMMIT, MO 640642615 NE MCBAINE DR, LEES SUMMIT, MO 640642617 NE
MCBAINE DR, LEES SUMMIT, MO 640642601 NE MCBAINE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Commercial	Khanh Nguyen	Failed	Tuesday, September 13, 2022

Corrective Action Required:

1	Misc	Provide updated plan for change to gas piping size. Pressure test holds for min ten minutes
---	------	---

Comments: