

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20220620  
Address: 2605 NE MCBAINE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                | Inspector:   | Outcome: | Date:                       |
|--|--------------|----------|-----------------------------|
| <b>Gas Service Inspection - Commercial</b> | Khanh Nguyen | Failed   | Tuesday, September 13, 2022 |

Corrective Action Required:

|   |      |   |
|---|------|---|
| 1 | Misc | Provide updated plan for change to gas piping size. Pressure test holds for min ten minutes |
|---|------|---|

**Comments:**