

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215503
Address: 142 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Wednesday, September 14, 2022

Corrective Action Required:

1	Miscellaneous Correction	Provide splash blocks 36" north side SUBMIT BACKFLOW CERTIFICATION LAWN IRRIGATION PERMIT Remove paper backing from insulation or provide approved cover unfinished portion of basement
---	-----------------------------	--

Comments: