

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20221447  
Address: 524 SE CARTER RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Patrick Schonfeldt	Failed	Wednesday, September 14, 2022

Corrective Action Required:

1	Misc	-fireblock plumbing chases at garage -seal penetrations at fireblock furred down soffit end garage wall -top plate corner lap connection as required by code - see garage wall (different wall heights) -LIB bracing bed#5 per plans
---	------	---

Comments: