

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215066

Address: 2102 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822104 SW HOLDBROOKS DR, LEES SUMMIT,
MO 640822106 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822108 SW HOLDBROOKS
DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Wednesday, September 14, 2022

Corrective Action Required:

1	Misc	UNIT 2102: OK UNIT 2104: PROVIDE SCREW PATTERN AT ALL GB BRACED LOCATIONS PER PLANS/ IRC R602.10.4, 7" OC EDGES (INCLUDING TOP AND BOTTOM PLATES) AND 7" OC FIELD UNIT 2108: PROVIDE SCREW PATTERN AT ALL GB BRACED LOCATIONS PER PLANS/ IRC R602.10.4, 7" OC EDGES (INCLUDING TOP AND BOTTOM PLATES) AND 7" OC FIELD
---	------	---

Comments: