

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213548
Address: 2100 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Robb Popp	Partial	Wednesday, September 14, 2022

Corrective Action Required:

1	THIRD FLOOR	AREA A -Secure, support and install missing RC in units and storage areas
---	-------------	--

Corrective Action Required:

2	SECOND FLOOR
---	--------------

Corrective Action Required:

3	FIRST FLOOR	AREA B -CLUBHOUSE TRUSSES OK FOR PRE ROCK
---	-------------	--

Comments: