

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20212244
Address: 890 NE LANGSFORD RD, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Michael Harkins	Failed	Wednesday, September 14, 2022

Corrective Action Required:	
1 Misc	-SCREW PATTERN AT DATA ROOM BOTH SIDES
Corrective Action Required:	
2 Miscellaneous Correction	SEAL PENETRATIONS 1 HOUR WALL IN DATA ROOM

Comments: