CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212683
Address: 1033 SW REDBUCK CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Wednesday, September 14, 2022

Corrective Action Required:

1	Miscellaneous Correction	- Complete latch on garage entry door - Outlet dead north bedroom at bathroom counter - Provide ani siphon device - Add gravel to Egress window well - Label all non gfci outlets - Humidifier not connected to water - Provide handrail for basement stairs - Step at sliding door to patio has more than 3/8” variance - Sump discharge minimum of 36” away from foundation - Provide splash blocks - Address shall be contrasting in color - Top step on front entry out of compliance - Obtain an irrigation permit and submit a back flow certification

Comments: