

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214607

Address: 902 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081904 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081906 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081908 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081910 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081900 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Michael Harkins	Failed	Wednesday, September 14, 2022

Corrective Action Required:

1	Miscellaneous Correction	900 Black Twig Cir Anchor bolts garage portal frame ? Fire caulk / fire block
		902 Fire block top plate kitchen Seal fire blocking master bedroom Seal top plate master bath & hall bath tub
		904 Fire bloxking / fire caulk
		906 Fire blocking / fire caulk
		908 Fire blocking / fire caulk

910

Provide ufer access & connect grounding electrode to disconnect

Complete sec feeders

Provide H2.5s above stair landing

Seal duct work at ceiling in dead space bedroom closet & above tub

Comments: