



PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #:PRPWRW20223891, Public Works Right of Way Permit
Address: 256 NE EDGEWATER DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Site Visit Inspection	Bob Burns	Failed	Thursday, September 08, 2022

Corrective Action Required

1	Misc	Driveway depth, forms, and gravel meet specs. This will need an ADA final inspection.
---	------	---

Corrective Action Required

2	Misc	site visited and it appears that ADA does not meet city standards. The sidewalk is as high as 4.1% in areas. The driveway will need to be tore out and replaced to meet ada standards.
---	------	--

Comments: