

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220348
Address: 2621 SW HOOK FARM LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------------|----------|------------------------------|
| All Rough Inspection - Residential | Mitchell Schwarz | Failed | Thursday, September 15, 2022 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">-Address rafters landing on blocks throughout provide engineering-address rafters to ceiling joist connections throughout provide engineering-address top plate penetration NE garage wall-protect NM Within 6' of attic access-address over bored studs for service entry in garage nail off stud shoes-seal gaps and penetrations into furr down in pantry (see beam and entry wall)-all anchor bolts in basement to be tight-seal gap in fire block in bed 4 S wall-mid way strap 2" dwv in bed 4 closet-seal penetrations in RA joist space above basement linen closet-seal penetrations in bed 3 closet to ceiling space-seal penetrations in RA joist space above bed 3-bond gas line |
|---|------|--|

Comments: