

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20216411
Address: 710 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Robb Popp	Failed	Thursday, September 15, 2022

Informational:

1	Misc	-Verified rated plywood at exterior walls
---	------	---

Corrective Action Required:

2	Misc	-Extend wall to deck above on all sides and complete screw pattern and drywall
---	------	--

Comments: