

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214638
Address: 2110 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Thursday, September 15, 2022

Corrective Action Required:

1	Miscellaneous Correction	Maintain gutter buddy at curb inlet Submit as graded plot plan Raise grade or provide guardrail at front stoop over 30" Provide spark rings backsplash kitchen Insulate floor joist cavity at HVAC air return rear wall basement Window Fall protection above window seat Per 2018 IRC R312.2.1
---	--------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: