CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215066 Address: 2102 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822104 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822106 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822108 SW HOLDBROOKS DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection	1:	Inspector:	Outcome:	Date:
All Rough Residentia	Inspection - al	Mitchell Schwarz	Not Ready	Thursday, September 15, 2022
Corrective	Action Required:			
1	Misc	UNIT 2102: OK		
		UNIT 2104: OK		
		UNIT 2106: PROVIDE SCRE	W PATTERN AT ALL GB BRAC	ED LOCATIONS PER
		PLANS/ IRC R602.10.4, 7" (DC EDGES (INCLUDING TOP A	AND BOTTOM PLATES)
		AND 7" OC FIELD		
		UNIT 2108: PROVIDE SCRE	W PATTERN AT ALL GB BRAC	ED LOCATIONS PER
		PLANS/ IRC R602.10.4, 7" (AND 7" OC FIELD	DC EDGES (INCLUDING TOP A	AND BOTTOM PLATES)

Comments: