

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213712
Address: 1909 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Ryan Heckman	Passed	Friday, September 16, 2022

Informational:

1 Misc

On 5.4.2022 I performed a sidewalk inspection and passed the subgrade to pour concrete. Temp 50 degrees

9-16-22 RH. Sidewalk meets LS and ADA specification.

Comments: