

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215616
Address: 2103 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|-----------------|----------|----------------------------|
| Occupancy Inspection - Codes Residential | Michael Harkins | Failed | Friday, September 16, 2022 |

Corrective Action Required:

| | | |
|---|--------------------------|--|
| 1 | Miscellaneous Correction | Pay not ready fees Sidewalk inspection still pending Provide guardrail or raise grade to less than 30" front stoop Remove dust covers smoke detectors Nail joist hanger under deck landing Provide 1 1/2 bearing deck beam Provide (2) through bolts deck beam to post connection Provide tamper proof caps AC condenser Clean street & curbs of dirt & debris |
|---|--------------------------|--|

Comments: