

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212569  
Address: 2353 SW HICKORY LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Friday, September 16, 2022

Corrective Action Required:

1	Misc	-address pending driveway inspection -obtain lawn irrigation permit -sod -splash blocks and sump pump discharge to extend 36" from foundation -outlet at garage entry, and unfinished area left of water heater to be GFCI protected or labeled non GFCI and switches to single receptacle outlet
---	------	---

**Comments:**