CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20220956 Address: 520 NE TOWN CENTRE DR, Unit:A, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:	
Water Line - Construction Inspection		Adam Nacke	Partial	Friday, September 16, 2022	
Informat	tional:				
1	Misc		8-29 to 9-6 AN. Site rite has been install the private fire line and have the south , west and north line in . Two more fire hydrant still have to be installed.		
		-	ackflow vault still needs to be installed		
			Backflow vault still needs to be installed		
		9/16/22 SR Backfow hydrostatic test som	• •	d and will be looking for a	

Comments: