CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210263

Address: 1801 NW OBRIEN RD, LEES SUMMIT, MO 64081520 NW HOPE LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Pavement-Aggregate Base Eric Sharp Passed Friday, September 16,

2022

Informational:

1 Misc Kaw Valley rolled out Tenax 302 geo grid and covered it with 6 inches of AB3.

RP 7-15-21

Informational:

2 Misc Kaw Valley rolled out Tenax 302 geo grid and covered it with 6 inches of AB3.

RP 7-15-21

Informational:

3 Misc Geo grid was laid today, with intention of laying base aggregate on top

tomorrow in preps for paving Friday. 9/14/22 ES

Kaw Valley completed laying rock base and performed a proof roll with SR

present. 9/15/22 ES

Comments: