

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220900

Address: 1035 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811037 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811039 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811041 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811043 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811045 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811047 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811049 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811051 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811053 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811055 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811033 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---------------------------------|------------|----------|----------------------------|
| Sewer Service Inspection | Eric Sharp | Partial | Friday, September 16, 2022 |

Informational:

1 Misc

Tied this buildings northern sanitary connection into line running along with building 11 line using a 6" wye connection and 6" SDR26 to main connection.
9/9/22 ES

Comments: