

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220895

Address: 1061 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811063 NW BLACK TWIG CIR, LEES SUMMIT, MO
640811065 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811059 NW BLACK TWIG CIR,
LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sewer Service Inspection	Eric Sharp	Passed	Friday, September 16, 2022

Informational:

1 Misc

Tied this buildings sanitary connection on south side into line running along with building 9 line using a 6" wye connection and 6" SDR26 pipe to 6" wye main connection. 9/9/22 ES

Comments: