

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213953
Address: 1517 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Monday, September 19, 2022

Corrective Action Required:

1	Misc	-maintain erosion control on lot, address before reinspection, clean all mud along street/curb line -final grade and sod -splash blocks -Sump pump discharge 36" from foundation -check kitchen countertop GFCI receptacles, not getting voltage for testing
---	------	--

Comments: