

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220586
Address: 908 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Michael Harkins	Failed	Monday, September 19, 2022

Corrective Action Required:

1	Miscellaneous Correction	- PROVIDE UFER GROUND, NO METER CAN OR DISCONNET, CABINETS AT THIS TIME -
---	--------------------------	---

Comments: