CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214054

Address: 4716 NE FREEHOLD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Khanh Nguyen Failed Monday, September

Residential 19, 2022

Corrective Action Required:

1 Misc -Obtain lawn irrigation permit and submit backflow valve test report to city

-are-inspection fees must be paid in full prior to any occupancy

-As-graded plot plan is required

-Provide sewer tracer wire port at grade

-Garage door not self-closing

-2nd fl rear bathroom receptacle not gfci-protected

-Stair to basement, provide min 6'8" headroom clearance from light above

stair, or install luminaire no more than 4" protruding from wall

-Screw the basement exterior door embedded jamb brace into studs

-Install sump pump cover

-Support lawn irrigation pex line every 32" horizontally -Fb floor at master bathroom tub trap above sump pump

-Install airtight cap for the sewer clean out

Comments: