

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213548
Address: 2100 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Partial	Monday, September 19, 2022

Corrective Action Required:

1	THIRD FLOOR	AREA "A" UNITS AND CORRIDOR APPROVED AREA "B" 329-joist hangers at deck, 4' fire set back at shaft wall-ADD CLEATS 327- nail h2.5 at bedroom 319 strap top plate at Smurf tube 317-truss hangers at patio-install missing nails
---	-------------	---

Corrective Action Required:

2	SECOND FLOOR	AREA A 209- Seal dead space 233- Nail corners
---	--------------	---

Corrective Action Required:

3	FIRST FLOOR	AREA A 9/2/22 UNITS 123,124,125,126,127,128,130,132,134
---	-------------	---

Corrective Action Required:

4	ELEVATOR 1	
---	------------	--

Corrective Action Required:

5	STAIR TOWER 1	-PROVIDE VERTICAL FIREBLOCKING MAX 10' OC AT SHARED WALL
---	---------------	--

Corrective Action Required:

6	STAIR TOWER 2	-PROVIDE VERTICAL FIREBLOCKING MAX 10' OC AT SHARED WALL
Corrective Action Required:		
7	STAIR TOWER 3	
Corrective Action Required:		
8	STAIR TOWER 4	

Comments: