

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220870
Address: 900 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Michael Harkins	Passed	Monday, September 19, 2022

Corrective Action Required:

1	Miscellaneous Correction	- STORM LINE PRESSURE STEADY AT 8 PSI UNDERSLAB PLUMBING STEADY AT 10 PSI
---	-----------------------------	--

Comments: