

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20212244  
Address: 890 NE LANGSFORD RD, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Michael Harkins	Failed	Monday, September 19, 2022

Corrective Action Required:

1	Miscellaneous Correction	Provide cover open circuit breaker service panel Install ceiling tiles Label RTU disconnect to match service panel RTU GFCI not working Complete media wall Install backordered glass entry door Label service panel Provide documentation Clarifying atm footing inspection Pending field engineering, fire, planning Approval  Ok to move furniture in NO OCCUPANCY
---	--------------------------	---

**Comments:**