

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20216173  
Address: 2039 SW HOOK FARM DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Tuesday, September 20, 2022

Corrective Action Required:

1	Misc	-obtain lawn irrigation permit -sod -gutters -splash blocks and sump pump discharge to extend 36" from foundation -provide access to jacuzzi tub in master pump motor and GFCI outlet to code -handrail required at 2nd floor loft area -stairs at 2nd story loft area greater than 3/8 difference in rise -address electrical at hot water heater
---	------	---

Comments: