

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215869
Address: 2103 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, September 20, 2022

Corrective Action Required:

1	Misc	-install secondary locking devices at rear sliders -support water heater vent -protect engineered i joist in unfinished spaces per code -security screws at rear patio door to security code -address deck post to beam connections
---	------	---

Comments: