

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220402
Address: 4404 SW GRINDSTONE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, September 20, 2022

Corrective Action Required:

1	Misc	-seal all penetrations through air returns - See joist cavity penetrations -provide 3" SCH 40 steel column at garage steel beam per plans -2x10 joist split at pantry -provide all truss hangers per plans -1st floor breakfast -provide 1" clearance at b vent basement
---	------	--

Comments: