

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215064
Address: 3713 SW MARYVILLE PL, LEES SUMMIT, MO 640823715 SW MARYVILLE PL, LEES SUMMIT, MO
640823717 SW MARYVILLE PL, LEES SUMMIT, MO 640823711 SW MARYVILLE PL, LEES
SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Tuesday, September 20, 2022

Corrective Action Required:

1	Misc	-splash blocks -Sump pump discharge 36" from foundation -Uncover manhole covers MH 7-2 and MH 7-1 at front of lot as shown on plot plan
---	------	---

UNIT 3717: OK FOR TCO

UNIT 3715: OK FOR TCO

UNIT 3713: OK FOR TCO

UNIT 3711: OK FOR TCO

Comments: