

David P. Ainsworth, P.E.
1200 NW Hearnese Ave, Blue Springs, MO 64015
Cell Phone: 816-682-2093
Email: dainsworth@chelepis.com

September 6, 2022
Mr. Tracy Ferren
Mill Creek Builders Inc
21203 W 81st Terrace
Lenexa, KS 66220

Re: 1514 SW Heartwood Dr
Lee's Summit, MO
Woodglen Addition Lot 2
Permit 2021-0734
Deck Support Post Pier Inspection

Dear Mr. Ferren:

On September 6, 2022, I inspected the above referenced property to inspect piers for the deck support posts.

The piers are about 24" diameter and the base of the piers is about 3' below the final finish grade.

The piers are properly prepared and will be adequate for the deck support posts.

Cordially,



David P. Ainsworth, P.E.

