

*David P. Ainsworth, P.E.*  
*1200 NW Hearn Ave, Blue Springs, MO 64015*  
*Cell Phone: 816-682-2093*  
*Email: dainsworth@chelepis.com*

September 6, 2022  
Mr. Tracy Ferren  
Mill Creek Builders Inc  
21203 W 81<sup>st</sup> Terrace  
Lenexa, KS 66220

Re: 1518 SW Heartwood Dr  
Lee's Summit, MO  
Woodglen Addition Lot 1  
Permit 2021-0742  
Deck Support Post Pier Inspection

Dear Mr. Ferren:

On September 6, 2022, I inspected the above referenced property to inspect piers for the deck support posts.

The piers are about 24" diameter and the base of the piers is about 3' below the final finish grade.

The piers are properly prepared and will be adequate for the deck support posts.

Cordially,



David P. Ainsworth, P.E.

