

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20220902
Address: 520 NE TOWN CENTRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Construction Inspection	Adam Nacke	Passed	Wednesday, September 21, 2022

Informational:
1 Misc 09/21/22 Wednesday JMJ (Genesis Plumbing)
Contractor performed tie-in on existing 12" water main with 12"X12" tee and 2/12" sleeve.
Tie-in was perform from 6:20AM to 10:20AM.

Comments: