## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

## Permit #: PRCOM20220899

Address: 1024 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811026 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811028 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811030 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811032 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811034 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811036 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811038 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811040 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811042 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811044 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811046 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811022 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Robb Popp	Partial	Wednesday, September 21, 2022
Informational:			
1 Misc	Main sanitary line ok to cover between joints		

Main sanitary line ok to cover between joints
perform air or water column test when dwv is complete

**Comments:**