



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20110360, Building Permit - Commercial
Address: 970 NW BLUE PKWY, Unit:A, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Electrical Inspection - Commercial	Mark Harding	Partial	Wednesday, April 13, 2011

Corrective Action Required
1 MISC

PENDING - CHANGE PLANS TO SHOW 3 5/8" STUDS INSTALLED
PLANS SHOW 6".

OK TO COVER PENDING CHANGE

Comments: