



Sprinkler Legend											
SYMBOL	MANUFACTURER	SIN	MODEL	QUANTITY	K-FACTOR	TYPE	SIZE	RESPONSE	FINISH	TEMPERATURE	NOTE
	VIKING	VK302	S.C. PENDENT	51		5.6 PENDENT	½	QUICK	CHROME	155°F	130 SQ. FT.
				TOTAL = 51							

WET SYSTEM
ORDINARY HAZARD

DESIGN PROFESSIONAL OF RECORD



1. DESIGN IS BASED ON 2016 NFPA 13 FOR INSTALLATION & NFPA 25 FOR MAINTENANCE.
2. ALL SPRINKLER MATERIAL TO COMPLY WITH UL LISTINGS, ALL AHJ REQUIREMENTS, AND NFPA STANDARDS.
3. CONTINUOUS CENTRAL MONITORING OF SPRINKLER SYSTEMS PER NFPA 72 TO BE BY OTHERS.
4. ALL VALVES TO BE MONITORED BY TAMPER SWITCHES.
5. ALL ELECTRICAL WIRING TO BE BY OTHERS.
6. ANY UNDERGROUND PIPE WORK TO BE BY OTHERS.
7. ALL PAINTING OF SPRINKLER PIPE TO BE BY OTHERS.
8. ALL PATCHING AND/OR PAINTING OF PENETRATED DRYWALL AND MASONRY WALLS TO BE BY OTHERS.
9. ADEQUATE HEAT TO BE MAINTAINED TO PREVENT PIPE FREEZING.
10. THIS BUILDING IS UNOCCUPIED NONCOMBUSTIBLE CONSTRUCTION.
11. ORIGINAL WET TYPE SYSTEM DESIGNED AT ORDINARY HAZARD.
12. NEW PIPE TO BE 1" UNO
13. NEW WORK DOES NOT AFFECT HYDRAULICALLY REMOTE AREA.

[illegible]

Alliance
FIRE PROTECTION
 130 W 9TH AVE. SUITE 101
 NORTH KANSAS CITY, MO 64116
 PH: 913-888-0647 FAX: 913-888-0618

Camm Construction
344 NW Capital Dr
Lee's Summit, MO 64086

CONTRACTOR

Deerbrook Plaza

1125 NE Rice Road
Lee's Summit, MO 64086

PROJECT

AHJ
Lee's Summit, MO FM
DESIGNER
AKC
SCALE
1/4" = 1'-0
TOTAL SPRINKLERS ON JOB
51
JOB NUMBER
FP25294
DATE
09/12/22
SHEET NUMBER
FP 1 OF 1