

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215064  
Address: 3713 SW MARYVILLE PL, LEES SUMMIT, MO 640823715 SW MARYVILLE PL, LEES SUMMIT, MO  
640823717 SW MARYVILLE PL, LEES SUMMIT, MO 640823711 SW MARYVILLE PL, LEES  
SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Not Ready	Wednesday, September 21, 2022

Corrective Action Required:

1	Misc	-splash blocks -Sump pump discharge 36" from foundation -Uncover manhole covers MH 7-2 and MH 7-1 at front of lot as shown on plot plan -Pay inspection fee
---	------	--

UNIT 3717: OK FOR TCO

UNIT 3715: OK FOR TCO

UNIT 3713: OK FOR TCO

UNIT 3711: OK FOR TCO

**Comments:**